Battelle
. . . Putting Technology To Work

COPY

HPS #: J-17029

HEALTH PHYSICS SURVEY REPORT

DATE 12-3-99	INSTRUMENTATION USED		
TIME 1430	MODEL	S/N	CAL. DATE DUE
SURVEYOR B. Johns / W. O'Steen.	RO-20	2789	1-6-00
LOCATION JN2 Spent Fuel Pool	Electra	93601	3-3-00
REVIEWED BY C. D. Chapman		N/A	
Smear locations circled; Dose Rates = mR/hr	WI # 924	RWP # 99-JNO-050	

PURPOSE OF SURVEY: Pool Liner Installation



SMEAR RESULTS
RESULTS = DPM/100CM² UNLESS NOTED

#	βγ	α
1 I/s Liner	<1k	ND
2	<1k	ND
3	<1k	ND
4 I/s Liner	<1k	ND
5 WALL	<1k	ND
6 WALL	<1k	ND
7 I/s Basket	<1k	ND
8 O/s Basket	<1k	ND
9 North Floor	<1k	ND
10 North	<1k	ND
11 East	<1k	ND
12 East	<1k	ND
13 west	<1k	ND
14 @ SOP Floor	<1k	ND
15 per 1649		

CHECK IF APPLICABLE
- ☒ SEE ATTACHED DDO-134 FOR SMEAR RESULTS.
- ☒ SEE ATTACHED DDO-103 FOR ADDITIONAL INFORMATION.
- ☐ SEE ATTACHED DDO-057 FOR A/S RESULTS. NUMBER OF A/S(s) ATTACHED: 23
- ☐ RAL RESULTS ATTACHED

Gross Masslinn RESULTS
RESULTS = DPM/WIPE UNLESS NOTED

A) I/s Pool	<1k	ND
B) Man Basket	<1k	ND
C) HPZ-II Floor	<1k	ND
D) FLOOR	<1K	ND
E) FLOOR	<1K	ND
	N	
	A	

β - Dose Rates in mRad / Hr.
☐ L-3 / ☐ DELTA 3 / ☐ ELECTRA BKG: 1 Beta Correction Factor: 3.4
CPM α, 514 CPM β EFF: 22.96 % α 10.2 % β

DDO-138